

64-10-WHSS-60- 1/8” Stainless Steel Wheels n’ Heels® InVent® Gratings

Model Specification for type 64-10-WHSS-60 1/8”Stainless Steel Grating as
Manufactured by Ohio Gratings, Inc.™ 5299 Southway St. SW, Canton, Ohio 44706 or
approved equal.

NOTE: The specifier will need to edit this specification to reflect the options in this
document shown in **Red**. Some editing can be accomplished by deleting unnecessary
requirements.

SECTION 05 53 00 Metal Fabrications – Metal Gratings

Part 1: General

1.1 Section Includes

- A. Prefabricated heavy duty ADA compliant stainless steel bar gratings.
- B. Prefabricated Support Frames for gratings.
- C. Miscellaneous installation hardware and accessories.

1.2 References

- A. ASTM A-666 Stainless Steel Strip
- B. ASTM A-269 Stainless Steel Tubing
- C. ASTM A-967 Standard for Chemical Passivation for Stainless Steel
- D. ANSI/NAAMM- MBG-532-09 Heavy Duty Metal Bar Grating Manual
- E. US Dept. of Justice Americans with Disabilities Act- 2010 Design Standards
Section 302 for bar spacing and slip resistance.
- F. ANSI-NFSI B101.3-2012 Test Method for Measuring Wet Dynamic Coefficient
of Friction (Wet DCOF) of Common Hard-Surface Floor Materials

1.3 Action Submittals

- A. Product Data: The contractor shall submit the manufacturer’s product detail
data including load tables, anchor details and standard installation details.
- B. Shop drawings: The contractor shall submit for approval shop drawings for the
fabrication and erection of all gratings, based on construction drawings of current
issue. Include plans, elevations, and details of sections and connections as
required. Show type and location of all fasteners.
- C. Samples of Grating and Anchorage system shall be submitted for approval.

1.4 Quality Assurance

- A. Manufacturer Qualification: A company specializing in the manufacture of metal bar gratings with not less than 10 years of documented experience.
- B. Fabrication tolerances shall be in accordance with applicable provisions and recommendations of ANSI/NAAMM 532-09 Metal Bar Grating Manual.

Part 2: Products

2.1 Source Requirements:

Design is based upon use of gratings as manufactured by Ohio Gratings and terminology used herein may include reference to the specific performance or product of this manufacturer. Such reference shall be construed only as establishing the quality of materials, operational features and workmanship to be used under this Section and shall not, in any way, be construed as limiting competition.

2.2 Manufacturers:

Acceptable Manufacturers include Ohio Gratings, 5299 Southway St. SW, Canton, Ohio 44706, 800.321.9800, www.ohiogratings.com, or approved equal.

2.3 Manufactured Units:

- A. **Description:** Grating: Type **64-10-WHSS-60 1/8"** Wheels n' Heels® InVent® Heavy Duty Stainless Steel Grating with OnGrip® Spray Traction Surface, Sandblasted SP6 and Passivated finish. Fabricated by assembling tubular stainless steel cross bars through round holes in **1/8"** thick rectangular top surface bars space **5/8"** on center and **1/8"** thick rectangular heavy cross bars space **3-3/4"** on center that are then permanently locked in place by swaging. Heavy duty main bearing bars are 4" on center inserted beneath and perpendicular to the top surface bars then fillet welded at each main bearing bar / heavy cross bar intersection.
1. Top surface bar Spacing: **5/8"** on center.
 2. Top surface bar depth is 1" and thickness is **1/8"** to provide **1/2"** space between bars.
 3. Main Bearing Bars **1/4"** thick spaced 4" on center and their depth is to be based on loading requirements and the clear span shown on the drawings. Main bearing bars are perpendicular to top surface bars.
 4. Heavy Duty Cross Bars 1-1/2" x **1/8"** are flush with top surface and spaced **3-3/4"** on center.
 5. All Top Surface bars shall have OnGrip® Spray Traction Surface.
- B. **Fabrication:** Load Band ends of grating with bars **1/8"** thick welded flush with the top surface of the grating and **1/2"** less than the overall depth of the grating as shown on the drawings. **Include welded anchor blocks flush with the top surface with counter sunk hole to accept washer and attachment bolts.**
- C. **Stainless Steel Frames:** Stainless Steel frames shall be provided as shown on the contract drawings to support and attach the gratings. **Include anchors as shown for locking frame into concrete as shown on the plans.**

D. Design Criteria:

1. **Loading:** Unless shown otherwise on the contract drawings, gratings shall be designed and manufactured to meet the live load conditions of **AASHTO HS 20 with 30% impact factor**. Main Bearing bar depth shall be as shown on the contract drawings or as recommended by the manufacturer to meet the loading requirements, and clear span conditions.
 2. **Traction / Slip Resistance:** When tested per ANSI-NFSI B101.3-2012, the top surface shall provide a minimum Wet Dynamic Coefficient of Friction (Wet DCOF) of 0.45 to meet High Traction classification. Also, per ADA section 302.1, walking surfaces shall provide a slip-resistant surface with sufficient frictional counterforce to the forces exerted in walking to permit safe ambulation.
 3. **Top Surface Bar Orientation:** Per ADA section 302.3, the gratings shall be oriented with the top surface bearing bars perpendicular to the predominate direction of pedestrian travel.
- E. Materials:** Main bearing bars, top surface bars, banding bars, and heavy duty cross bars are Stainless Steel type **304** per ASTM A-666 Stainless Steel Tube Cross Bars are type **304** per ASTM A-269. Frames are stainless steel type **304**.
- F. Fabrication Tolerances** shall be in accordance with ANSI/NAAMM MBG 532-09 Metal Bar Grating Manual.
- G. Top Surface:** OnGrip® Spray Traction Surface shall be supplied in order to meet or exceed the Wet Dynamic COF requirements of paragraph 2.3 D.2 above.
- H. Finish:** Gratings shall be Sandblast finished to SP6 after fabrication and Passivated per ASTM A-967

2.4 Accessories:

Provide appropriate fasteners for type, grade, and class required for the approved anchorage system. Include lifting devices as shown on the drawings.

Part 3: Execution

3.1 Field Verification: Contractor is to provide field measurements prior to preparation of final shop drawings and fabrication where required to ensure proper fitting of the work.

3.2 Installation

A. Prior to grating installation, contractor shall inspect supports for correct alignment and conditions for proper attachment and support of the gratings. Any inconsistencies between contract drawings and supporting structure deemed detrimental to grating placement shall be reported in writing to the Engineer, Architect or owner's agent prior to placement.

B. Install grating in accordance with shop drawings and standard installation clearances as recommended by ANSI/NAAMM MBG-532-09 Metal Bar Grating Manual.

3.3 Grating Attachment: Use approved attachment system and fasteners to secure grating to supporting members as shown on plans.